



RURAL DRINKING WATER&SANITATION DEPARTMENT, GoK
WATER QUALITY TESTING LABORATORY YADGIR
 Railway Station Road Near Railway Station, Yadgir-585-202
 Email ID: rdwsd.wqmstp.yadgirlab@gmail.com



TC-11626

WATER QUALITY TEST REPORT

Report No : YDG25JUN0299	Report Issued Date: 07/09/2026
To, D DEVARAJ URS HPS AND HS TAHASIL BESIDE WADGERA Dist - YADGIR	ULR No: TC-11626000003001F
	Sample code: YDG25JUN0299
	Sample receipt date: 05/09/2026
	Date of Sample collection: 04/09/2026
	Analysis start date: 05/09/2026
	Analysis completion date:07/09/2026
	Environmental Condition:23+5
	Sample collection protocol: IS 10500 :2012
	Group Water Discipline Chemical Parameter

Sample :Water	Sample Type: SW	Sample Quantity: 1 Liter		
----------------------	------------------------	---------------------------------	--	--

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Test Method
-------	------	---------	--	---	-------------

Description: Clear Sample					
1.	pH Value @25.4° C	6.94	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm	121	—	—	IS 3025 (Part-14) : 2023
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2018
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	05	1	5	IS 3025 (Part-10) :2023
7.	Total Dissolved Solids @ 105°C, mg/l	54	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	21.4	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO ₃ , mg/l	29.3	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	14.4	75	200	IS 3025 (Part-40) : 2024
11.	Magnesium as Mg, mg/l	5.2	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	12.8	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	21	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.110	1	1.5	APHA 24 rd Edition
15.	Nitrate as NO ₃ , mg/l	14	45	No relaxation	APHA 24 rd Edition
16.	Iron as Fe, mg/l	0.10	1	No relaxation	IS 3025 (Part-53) : 2024

Remark: The above given sample conforms Acceptable limits as per IS10500:2012 For The above tested parameters only

Analyzed by: Junior Analyst (Pradeep Chawan)	Authorized Signatory: Senior Analyst (Ravikumar)
---	---

Notes:

*****END OF THE REPORT*****

RDWSD/WQMSP/TeR/01

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

